

NATIONAL EXAMINATIONS DECEMBER 2013

07-Mec-A1 Applied Thermodynamics and Heat Transfer

3 Hours Duration

Notes :

1. If doubt exists concerning the interpretation of any question, the candidate is urged to make assumptions and clearly explain what has been assumed along with the answer to the question.
2. The examination is open book. As a consequence, candidates are permitted to make use of any textbooks, references or notes.
3. Any non-communicating calculator is permitted. However, candidates must indicate the type of calculator(s) that they have used by writing the name and model designation of the calculator(s) on the inside of the cover of the first examination book.
4. It is expected that each candidate will have copies of both a thermodynamics text and a heat transfer text in order to make use of the information presented in the tables and graphs contained.
5. The answers to five questions, either three questions from Part A and two questions from Part B or two questions from Part A and three questions from Part B, comprise a complete examination.
6. Candidates must indicate the answers that they wish to have graded on the cover of the first examination book. Otherwise the answers will be graded in the order in which they appear in the examination book(s) up to a maximum of three answers per section .
7. The answer to any question carries the same value in the grading .

Continued on Page 2


PART A - THERMODYNAMICS

1. (a) The pressure of an ideal gas in a container is decreased from 1380 kPa to 345 kPa. The initial temperature is 60°C, the polytropic exponent $n = 1.20$, the specific heat $C_p = 1.047 \text{ kJ/kgK}$ and the gas constant $R = 0.258 \text{ kJ/kgK}$. Calculate the change in enthalpy and internal energy.

(b) Air is compressed in a steady flow machine from 100 kPa and 27°C to 500 kPa. The heat loss is 11.2 kJ/kg. The reversible work required for isentropic compression between the initial state and the final state is 307.5 kJ/kg. The compression efficiency is 75%. Calculate the change in entropy of the air during the process.

2. Steam enters the high pressure turbine of a reheat cycle power plant at 3.5 MPa and 350° and expands to 0.5 MPa after which it is reheated to 350°C. The steam is then expanded through the low pressure turbine to 7.5 kPa. Liquid leaving the condenser at 30°C is pumped to 3.5 MPa and returned to the boiler. Each turbine is adiabatic with an efficiency of 85%. The pump efficiency is 80%. The total power output of the turbines is 1000 kW. Determine (a) the mass flowrate of the steam (b) the power required to drive the pump and (c) the thermal efficiency of the power plant.

3. The gas turbine power plant depicted at the right operates with 75% regenerator effectiveness and 80% compressor and turbine efficiency. Air enters the compressor at 100 kN/m² and 27°C. The pressure ratio is 5 and the turbine inlet temperature is 984°C. Considering all of processes to be ideal and neglecting the mass of the fuel added to the air, compute the cycle thermal efficiency. Sketch the process on a temperature entropy diagram.




4. Freon 12 flows in a refrigeration system at 0.04 kg/s. The refrigerant enters the compressor at 150 kPa and -10°C, leaves the compressor at 1.2 MPa and 75°C, enters the expansion valve at 1.15 MPa and 40°C and leaves the evaporator at 175 kPa and -15°C. The power to the compressor is 1.9 kW. Draw the process on T-s coordinates and determine (a) the change in the specific entropy of the refrigerant during compression (b) the capacity of the refrigeration system (c) the coefficient of performance of the refrigeration cycle and (d) the heat lost by the refrigerant passing through the compressor per unit mass.

Continued on Page 3

PART B - HEAT TRANSFER

5. A window is comprised of a single sheet of glass $\delta = 10 \text{ mm}$ thick. The temperature of the air inside of the building $T_i = 25^\circ\text{C}$ and the temperature of the air outside of the building $T_o = -15^\circ\text{C}$. Heat transfer at the inside and outside surfaces of the window is governed by the natural convection heat transfer coefficients h_i and h_o , respectively. Radiation heat transfer is negligible. Determine the rate of heat transfer through the window per unit area q'' .

6. The baseplate of the 1000 W iron depicted at the right which is 0.5 cm thick with a surface area of 0.03 m^2 has thermophysical properties $\rho = 2770 \text{ kg/m}^3$, $C_p = 875 \text{ J/k}^\circ\text{C}$ and $\alpha = 7.3 \times 10^{-5} \text{ m}^2/\text{s}$. Initially the iron is in thermal equilibrium with the surrounding air at 22°C . Assuming the surface heat transfer coefficient to be $12 \text{ W/m}^\circ\text{C}$ and assuming that 85% of the energy generated in the electrical heater is transferred to the baseplate, determine (a) how long it would take for the temperature of the baseplate to reach 140°C and (b) how long the heater will be off if the thermostat is set such that the electric heaters switch off at 140°C and on at 125°C .



7. A spherical thermocouple bead is situated at the centerline of a cylindrical duct diameter D units in diameter by L units in length halfway between the ends to measure the temperature of the gas flowing through it. Since the surface area of the spherical thermocouple bead is very small in comparison with the surface area of the duct, the relationship below predicts the configuration factor F_{b-d} between the thermocouple bead and the surface of the duct.

$$F_{b-d} = \frac{L}{\sqrt{(D^2 + L^2)}}$$

A thermocouple with a 3 mm diameter bead located in a 0.92 m long duct indicates that the gas temperature is 179°C when the duct temperature is 65°C . Heat is transferred from the gas to the thermocouple bead by convection at the rate of 790 W/m^2 . Determine the error in the thermocouple reading if the emissivity of the thermocouple bead $\epsilon_b = 0.7$ and the emissivity of the duct $\epsilon_d = 0.9$.

8. Hot water flows through the shell side of a counter flow tube in shell heat exchanger at the rate of 36 kg/min. The water enters at 80°C and exits at 50°C, heating helium having a specific heat of 5139 J/kg°C which enters the tubes of the heat exchanger at 30°C. The overall heat transfer coefficient is 115 W/m²°C and the heat exchanger surface area is 22 m². Determine the mass flowrate and the temperature of the helium leaving the heat exchanger.

The End

Mec-A1- December 2013 Appendix 1 of 3

Superheated Freon-12

Temp °C	ρ m^3/kg	h kJ/kg	s kJ/kg K	ρ m^3/kg	h kJ/kg	s kJ/kg K	ρ m^3/kg	h kJ/kg	s kJ/kg K
1.00 MPa									
50.0	0.013 366	210.162	0.7021	0.014 433	206.661	0.6812			
60.0	0.019 410	217.810	0.7254	0.015 463	214.805	0.7060	0.012 579	211.457	0.6876
70.0	0.020 397	225.319	0.7476	0.016 368	222.687	0.7293	0.013 448	219.822	0.7123
80.0	0.021 341	232.739	0.7689	0.017 221	230.398	0.7514	0.014 247	227.891	0.7353
90.0	0.022 251	240.101	0.7895	0.018 032	237.995	0.7727	0.014 997	235.766	0.7573
100.0	0.023 133	247.430	0.8094	0.018 812	245.513	0.7931	0.015 710	243.512	0.7785
110.0	0.023 993	254.743	0.8287	0.019 567	252.993	0.8129	0.016 393	251.170	0.7983
120.0	0.024 835	262.053	0.8473	0.020 301	260.441	0.8320	0.017 053	258.770	0.8183
130.0	0.025 661	269.369	0.8659	0.021 018	267.875	0.8507	0.017 695	266.334	0.8373
140.0	0.026 474	276.699	0.8839	0.021 721	275.307	0.8689	0.018 321	273.877	0.8558
150.0	0.027 275	284.047	0.9015	0.022 412	282.745	0.8867	0.018 934	281.411	0.8738
160.0	0.028 068	291.419	0.9187	0.023 093	290.195	0.9041	0.019 535	288.946	0.8914
1.20 MPa									
70.0	0.011 208	216.650	0.6959	0.009 406	213.049	0.6794			
80.0	0.011 984	225.177	0.7204	0.010 137	222.198	0.7057	0.008 704	218.859	0.6909
90.0	0.012 698	233.390	0.7433	0.010 884	230.835	0.7298	0.009 406	228.056	0.7166
100.0	0.013 366	241.397	0.7651	0.011 526	239.155	0.7534	0.010 035	236.760	0.7402
110.0	0.014 000	249.264	0.7839	0.012 126	247.264	0.7739	0.010 615	245.154	0.7624
120.0	0.014 608	257.035	0.8059	0.012 697	255.223	0.7944	0.011 159	253.341	0.7835
130.0	0.015 195	264.742	0.8253	0.013 244	263.094	0.8141	0.011 676	261.384	0.8037
140.0	0.015 765	272.406	0.8440	0.013 772	270.391	0.8332	0.012 172	269.327	0.8232
150.0	0.016 320	280.044	0.8623	0.014 284	278.642	0.8518	0.012 651	277.201	0.8420
160.0	0.016 864	287.669	0.8801	0.014 784	286.364	0.8698	0.013 116	285.027	0.8603
170.0	0.017 398	295.290	0.8975	0.015 272	294.069	0.8874	0.013 570	292.822	0.8731
180.0	0.017 923	302.914	0.9145	0.015 752	301.767	0.9046	0.014 013	300.598	0.8955
1.40 MPa									
1.60 MPa									
70.0	0.011 208	216.650	0.6959	0.009 406	213.049	0.6794			
80.0	0.011 984	225.177	0.7204	0.010 137	222.198	0.7057	0.008 704	218.859	0.6909
90.0	0.012 698	233.390	0.7433	0.010 884	230.835	0.7298	0.009 406	228.056	0.7166
100.0	0.013 366	241.397	0.7651	0.011 526	239.155	0.7534	0.010 035	236.760	0.7402
110.0	0.014 000	249.264	0.7839	0.012 126	247.264	0.7739	0.010 615	245.154	0.7624
120.0	0.014 608	257.035	0.8059	0.012 697	255.223	0.7944	0.011 159	253.341	0.7835
130.0	0.015 195	264.742	0.8253	0.013 244	263.094	0.8141	0.011 676	261.384	0.8037
140.0	0.015 765	272.406	0.8440	0.013 772	270.391	0.8332	0.012 172	269.327	0.8232
150.0	0.016 320	280.044	0.8623	0.014 284	278.642	0.8518	0.012 651	277.201	0.8420
160.0	0.016 864	287.669	0.8801	0.014 784	286.364	0.8698	0.013 116	285.027	0.8603
170.0	0.017 398	295.290	0.8975	0.015 272	294.069	0.8874	0.013 570	292.822	0.8731
180.0	0.017 923	302.914	0.9145	0.015 752	301.767	0.9046	0.014 013	300.598	0.8955
1.80 MPa									
2.00 MPa									
90.0	0.006 595	219.562	0.6823						
100.0	0.007 264	229.852	0.7103	0.005 231	220.529	0.6770			
110.0	0.007 837	239.271	0.7352	0.005 886	232.063	0.7075	0.004 324	222.121	0.6750
120.0	0.008 351	248.192	0.7582	0.006 419	242.208	0.7336	0.004 959	234.875	0.7078
130.0	0.008 827	256.794	0.7798	0.006 887	251.632	0.7573	0.005 456	243.661	0.7349
140.0	0.009 273	265.180	0.8003	0.007 313	260.620	0.7793	0.005 884	255.524	0.7591
150.0	0.009 697	273.414	0.8200	0.007 709	269.319	0.8001	0.006 270	264.846	0.7814
160.0	0.010 104	281.540	0.8390	0.008 083	277.317	0.8200	0.006 626	273.817	0.8023
170.0	0.010 497	289.589	0.8574	0.008 439	286.171	0.8391	0.006 961	282.545	0.8222
180.0	0.010 879	297.583	0.8752	0.008 782	294.422	0.8575	0.007 279	291.100	0.8413
190.0	0.011 250	305.540	0.8926	0.009 114	302.597	0.8753	0.007 584	299.528	0.8597
200.0	0.011 614	313.472	0.9095	0.009 436	310.713	0.8927	0.007 878	307.864	0.8775
2.50 MPa									
3.00 MPa									
3.50 MPa									
4.00 MPa									
120.0	0.003 736	224.863	0.6771						
130.0	0.004 325	238.443	0.7111						
140.0	0.004 781	249.703	0.7386						
150.0	0.005 172	259.904	0.7630						
160.0	0.005 522	269.492	0.7854						
170.0	0.005 845	278.684	0.8063						
180.0	0.006 147	287.602	0.8262						
190.0	0.006 434	296.326	0.8453						
200.0	0.006 708	304.906	0.8636						
210.0	0.006 972	313.380	0.8813						
220.0	0.007 228	321.774	0.8985						
230.0	0.007 477	330.108	0.9152						

Mec-A1- December 2013 Appendix 2 of 3

Superheated Freon-12

Temp °C	ρ m³/kg	h kJ/kg	s kJ/kg K	ρ m³/kg	h kJ/kg	s kJ/kg K	ρ m³/kg	h kJ/kg	s kJ/kg K
0.05 MPa				0.10 MPa				0.15 MPa	
-20.0	0.341 857	181.042	0.7912	0.167 701	179.361	0.7401	0.114 716	184.619	0.7318
-10.0	0.356 227	186.757	0.8133	0.175 222	183.707	0.7628	0.119 366	190.560	0.7543
0.0	0.370 508	192.567	0.8350	0.182 647	191.628	0.7849	0.124 932	196.762	0.7763
10.0	0.384 716	198.471	0.8562	0.189 994	197.628	0.8064	0.129 930	202.927	0.7977
20.0	0.398 863	204.469	0.8770	0.197 277	203.707	0.8275	0.134 873	209.160	0.8186
30.0	0.412 959	210.557	0.8974	0.204 506	209.866	0.8482	0.139 768	215.463	0.8390
40.0	0.427 012	216.733	0.9175	0.211 691	215.104	0.8684	0.144 625	221.835	0.8591
50.0	0.441 030	222.997	0.9372	0.218 839	222.421	0.8883	0.149 450	228.277	0.8787
60.0	0.455 017	229.344	0.9565	0.225 955	228.815	0.9073	0.154 247	234.739	0.8980
70.0	0.468 973	235.774	0.9755	0.233 044	235.285	0.9269	0.159 020	241.371	0.9169
80.0	0.482 917	242.282	0.9942	0.240 111	241.829	0.9457	0.163 774	248.020	0.9354
90.0	0.496 833	248.868	1.0126	0.247 159	248.446	0.9642			
0.20 MPa				0.25 MPa				0.30 MPa	
0.0	0.088 608	139.669	0.7320	0.069 752	138.644	0.7139	0.057 150	137.533	0.6984
10.0	0.092 550	195.378	0.7543	0.073 024	194.969	0.7366	0.069 984	194.034	0.7216
20.0	0.096 413	202.135	0.7760	0.076 218	201.322	0.7587	0.062 734	200.490	0.7440
30.0	0.100 228	208.446	0.7972	0.079 350	207.715	0.7801	0.065 413	206.969	0.7658
40.0	0.103 939	214.814	0.8178	0.082 431	214.153	0.8010	0.068 049	213.430	0.7369
50.0	0.107 710	221.243	0.8381	0.085 470	220.642	0.8214	0.070 635	220.030	0.8075
60.0	0.111 397	227.735	0.8578	0.088 474	227.135	0.8413	0.073 185	226.627	0.8276
70.0	0.115 055	234.291	0.8772	0.091 449	233.735	0.8608	0.075 705	233.273	0.8473
80.0	0.118 690	240.910	0.8962	0.094 398	240.443	0.8800	0.078 200	239.971	0.8665
90.0	0.122 304	247.593	0.9149	0.097 327	247.160	0.8987	0.080 673	246.723	0.8853
100.0	0.125 901	254.339	0.9332	0.100 238	253.936	0.9171	0.083 127	253.530	0.9038
110.0	0.129 483	261.147	0.9512	0.103 134	260.770	0.9352	0.085 566	260.391	0.9220
0.40 MPa				0.50 MPa				0.60 MPa	
20.0	0.045 836	198.762	0.7199	0.035 646	196.935	0.6999	0.030 422	202.116	0.7063
30.0	0.047 971	205.428	0.7423	0.037 464	203.814	0.7230	0.031 966	209.154	0.7291
40.0	0.050 046	212.095	0.7639	0.039 214	210.656	0.7452	0.033 450	216.141	0.7511
50.0	0.052 072	218.779	0.7849	0.040 911	217.484	0.7667	0.034 887	223.104	0.7723
60.0	0.054 059	225.483	0.8054	0.042 565	224.315	0.7875	0.036 285	230.062	0.7929
70.0	0.056 014	232.230	0.8253	0.044 184	231.161	0.8077	0.037 633	237.027	0.8129
80.0	0.057 941	239.012	0.8448	0.045 774	238.031	0.8275	0.033 995	244.009	0.8324
90.0	0.059 846	245.837	0.8638	0.047 340	244.932	0.8467	0.040 316	251.016	0.8514
100.0	0.061 731	252.707	0.8825	0.049 886	251.869	0.8656	0.041 619	258.053	0.8700
110.0	0.063 600	259.624	0.9008	0.050 415	258.845	0.8840	0.042 997	265.124	0.8882
120.0	0.065 455	266.590	0.9187	0.051 929	265.862	0.9021	0.044 181	272.231	0.9061
0.70 MPa				0.80 MPa				0.90 MPa	
40.0	0.026 761	207.580	0.7143	0.022 830	205.924	0.7016	0.019 744	204.170	0.6982
50.0	0.028 100	214.745	0.7373	0.024 068	213.290	0.7243	0.020 912	211.765	0.7131
60.0	0.029 387	221.854	0.7590	0.025 247	220.558	0.7459	0.022 012	219.212	0.7358
70.0	0.030 632	228.931	0.7799	0.026 380	227.766	0.7682	0.023 062	226.564	0.7575
80.0	0.031 843	235.997	0.8002	0.027 477	234.941	0.7388	0.024 072	233.856	0.7735
90.0	0.033 027	243.066	0.8199	0.029 545	242.101	0.8088	0.025 051	241.113	0.7987
100.0	0.034 139	250.146	0.8392	0.029 588	249.260	0.8183	0.026 003	243.355	0.8184
110.0	0.035 332	257.247	0.8579	0.030 612	256.428	0.8472	0.026 937	255.593	0.8376
120.0	0.036 458	264.374	0.8763	0.031 619	263.613	0.8657	0.027 851	262.839	0.8562
130.0	0.037 572	271.531	0.8943	0.032 612	270.829	0.8833	0.028 751	270.100	0.8745
140.0	0.038 673	278.720	0.9119	0.033 592	278.055	0.9016	0.029 639	277.381	0.8923
150.0	0.039 764	285.946	0.9292	0.034 563	285.320	0.9189	0.030 515	284.687	0.9093

Saturated Freon-12

Abs. Temp °C	Press. MPa <i>P</i>	Specific Volume m³/kg				Enthalpy kJ/kg				Entropy kJ/kg K		
		Sat. Liquid <i>v_f</i>	Evap. <i>v_{fg}</i>	Sat. Vapor <i>v_t</i>	Sat. Liquid <i>h_f</i>	Evap. <i>h_{fg}</i>	Sat. Vapor <i>h_t</i>	Sat. Liquid <i>s_f</i>	Evap. <i>s_{fg}</i>	Sat. Vapor <i>s_t</i>		
-90	0.0028	0.000 608	4.414 937	4.415 545	-43.243	139.613	140.375	-0.2084	1.0352	0.8958		
-85	0.0042	0.000 612	3.036 704	3.037 316	-33.968	137.608	148.640	-0.1354	0.9970	0.8116		
-80	0.0062	0.000 617	2.137 728	2.138 345	-34.688	135.612	150.934	-0.1630	0.9609	0.7979		
-75	0.0088	0.000 622	1.637 030	1.637 651	-30.401	133.625	153.224	-0.1411	0.9266	0.7355		
-70	0.0123	0.000 627	1.126 654	1.127 280	-26.103	131.640	155.536	-0.1197	0.8940	0.7744		
-65	0.0168	0.000 632	0.840 534	0.841 166	-21.793	179.651	157.857	-0.0987	0.8630	0.7643		
-60	0.0226	0.000 637	0.637 274	0.637 910	-17.489	177.653	160.134	-0.0782	0.8334	0.7552		
-55	0.0300	0.000 642	0.490 358	0.491 000	-13.129	175.641	162.512	-0.0581	0.8051	0.7470		
-50	0.0381	0.000 645	0.382 457	0.383 105	-3.772	173.511	164.340	-0.0334	0.7779	0.7396		
-45	0.0504	0.000 654	0.302 029	0.302 682	-4.396	171.533	167.163	-0.0190	0.7519	0.7329		
-40	0.0642	0.000 659	0.241 251	0.241 910	-0.000	169.479	169.479	-0.0000	0.7269	0.7269		
-35	0.0807	0.000 666	0.194 732	0.195 398	4.416	167.368	171.734	0.0137	0.7027	0.7214		
-30	0.1004	0.000 672	0.158 703	0.159 375	8.354	165.222	174.076	0.0371	0.6795	0.7165		
-25	0.1237	0.000 679	0.130 487	0.131 166	13.315	163.037	175.352	0.0552	0.6570	0.7121		
-20	0.1509	0.000 685	0.108 162	0.108 847	17.300	160.810	173.610	0.0730	0.6352	0.7082		
-15	0.1826	0.000 693	0.090 326	0.091 013	22.312	153.534	180.846	0.0906	0.6141	0.7046		
-10	0.2191	0.000 700	0.075 946	0.076 646	25.351	156.207	183.058	0.1079	0.5936	0.7014		
-5	0.2510	0.000 703	0.064 235	0.064 963	31.420	153.823	185.243	0.1250	0.5736	0.6936		
0	0.3036	0.000 716	0.054 673	0.055 339	36.022	151.376	187.397	0.1418	0.5542	0.6960		
5	0.3626	0.000 724	0.046 761	0.047 435	40.659	148.859	189.518	0.1585	0.5351	0.6937		
10	0.4233	0.000 733	0.040 180	0.040 914	45.337	146.265	191.602	0.1750	0.5163	0.6916		
15	0.4914	0.000 743	0.034 671	0.035 413	50.058	143.586	193.644	0.1914	0.4983	0.6897		
20	0.5673	0.000 752	0.030 023	0.030 780	54.828	140.812	195.641	0.2076	0.4803	0.6879		
25	0.6518	0.000 763	0.026 091	0.026 854	59.653	137.933	197.586	0.2237	0.4626	0.6863		
30	0.7449	0.000 774	0.022 734	0.023 508	64.539	134.936	199.473	0.2397	0.4451	0.6843		
35	0.8477	0.000 786	0.019 855	0.020 641	69.494	131.805	201.299	0.2557	0.4277	0.6834		
40	0.9607	0.000 798	0.017 373	0.018 171	74.527	128.525	203.051	0.2716	0.4104	0.6820		
45	1.0843	0.000 811	0.015 220	0.016 032	79.647	125.074	204.722	0.2875	0.3931	0.6806		
50	1.2193	0.000 826	0.013 344	0.014 170	84.868	121.430	206.298	0.3034	0.3758	0.6792		
55	1.3663	0.000 841	0.011 701	0.012 542	90.201	117.585	207.766	0.3194	0.3582	0.6777		
60	1.5259	0.000 858	0.010 253	0.011 111	95.665	113.443	209.109	0.3355	0.3405	0.6760		
65	1.6988	0.000 877	0.008 971	0.009 847	101.279	109.024	210.303	0.3518	0.3224	0.6742		
70	1.8858	0.000 897	0.007 823	0.008 725	107.067	104.255	211.321	0.3683	0.3038	0.6721		
75	2.0874	0.000 920	0.006 802	0.007 723	113.053	99.068	212.126	0.3851	0.2845	0.6697		
80	2.3046	0.000 946	0.005 875	0.006 821	119.291	93.373	212.663	0.4023	0.2644	0.6667		
85	2.5380	0.000 976	0.005 029	0.006 005	125.313	87.047	212.865	0.4201	0.2430	0.6631		
90	2.7835	0.001 012	0.004 246	0.005 258	132.708	79.907	212.614	0.4385	0.2200	0.6585		
95	3.0569	0.001 056	0.003 508	0.004 563	140.068	71.658	211.726	0.4579	0.1946	0.6526		
100	3.3440	0.001 113	0.002 790	0.003 903	148.076	61.768	209.843	0.4788	0.1655	0.6444		