

NATIONAL EXAMINATIONS DECEMBER 2014

07-Mec-A1 Applied Thermodynamics and Heat Transfer

3 Hours Duration

Notes :


1. If doubt exists concerning the interpretation of any question, the candidate is urged to make assumptions and clearly explain what has been assumed along with the answer to the question.
2. The examination is open book. As a consequence, candidates are permitted to make use of any textbooks, references or notes.
3. Any non-communicating calculator is permitted. However, candidates must indicate the type of calculator(s) that they have used by writing the name and model designation of the calculator(s) on the inside of the cover of the first examination book.
4. It is expected that each candidate will have copies of both a thermodynamics text and a heat transfer text in order to make use of the information presented in the tables and graphs contained.
5. The answers to five questions, either three questions from Part A and two questions from Part B or two questions from Part A and three questions from Part B, comprise a complete examination.
6. Candidates must indicate the answers that they wish to have graded on the cover of the first examination book. Otherwise the answers will be graded in the order in which they appear in the examination book(s) up to a maximum of three answers per section.
7. The answer to any question carries the same value in the grading .

PART A - THERMODYNAMICS

1.(a) Freon-12 vapour is contained in a sealed glass tube at 30°C (State 1). It is desired to know the pressure at this condition but in as much as the glass tube is sealed, it is not possible to measure it. The glass tube was immersed in a cooling bath in order to reduce its temperature and just as the temperature reached 10°C (State 2), small droplets of liquid were observed to form on the inside surface of the glass. Sketch the relationship between temperature T and specific volume v and locate State point 1 and State point 2 on the diagram. Determine the pressure at State 1.


1.(b) Nitrogen is compressed reversibly from 100 kPa and 20°C to 500 kPa. During the process, pressure p and specific volume v vary according to $p v^{1.3} = \text{constant}$. Determine the work and heat transfer per unit mass and show the process on p - v and T - s diagrams.

2. A steam turbine can be operated at part-load conditions by throttling the steam to a lower pressure before it enters the turbine. The line conditions are 1.4 MPa, 300°C and the turbine exhaust pressure is fixed at 10 kPa. Assuming the expansion inside the turbine to be reversible and adiabatic, determine the pressure to which the steam must be throttled to produce 75% of the full-work output.



3. Air entering the compressor of a gas turbine at a pressure of 100 kPa and a temperature of 300 K is compressed to 1000 kPa. The temperature of the air at the inlet of the first turbine stage is 1400 K. Then the air expands isentropically in two stages with reheat to 1400 K between the stages at a constant pressure of 300 kPa. A 100% effective regenerator is incorporated in the cycle. Determine the thermal efficiency.


4. Freon-12 is employed as the working fluid in a heat pump with an evaporator temperature of 5°C and a condenser temperature of 50°C. The compressor is 85% efficient. The heating requirements are 30,000 W. If electricity can be obtained at \$0.077/kWhr, choose between using the heat pump or heating with a furnace which is 70% efficient if fuel can be obtained at \$5.60 per million kJ.




PART B - HEAT TRANSFER

5. Steam flows through a copper tube having an outside diameter $D = 2.54 \text{ cm}$ and a wall thickness $\delta = 0.54 \text{ cm}$. The inside surface temperature $T_i = 100^\circ\text{C}$ and the temperature of the room in which the tube is located $T_o = 27^\circ\text{C}$. Determine the thickness of insulation having thermal conductivity $k = 0.0875 \text{ W/m}^\circ\text{C}$ required to reduce the heat loss to the surrounding air by 95% when the tube is cooled by forced convection heat transfer where $h = 55 \text{ W/m}^\circ\text{C}$. What would the outside surface temperature T_o be under these conditions ?

6. Water at $T_i = 20^\circ\text{C}$ enters a horizontal duct $H = 20 \text{ cm}$ high by $W = 20 \text{ cm}$ wide at a velocity of $V = 5 \text{ cm/s}$. The temperature of the ambient air surrounding the duct $T_o = 50^\circ\text{C}$. The heat transfer coefficient on the outer surface of the duct is $h = 150 \text{ W/m}^\circ\text{C}$. Determine the heat gained by the water over 1 m as well as the temperature of the water leaving the duct.



7. An ice rink 35 m long by 20 m wide is located in a building 60 m long by 50 m wide by 15 m high as indicated in the illustration. The temperature of the ice is maintained at -8°C , the temperature of the walls of the building is 16°C and the temperature of the air in the building is 10°C . The emissivity of the walls is 0.8 and the emissivity of the ice is 0.97. The heat transfer coefficient at the surface of the ice is $50 \text{ W/m}^\circ\text{C}$. Determine the rate at which heat must be removed from the concrete pad on which the ice is located to maintain these conditions.



8. Water at 230 kg/hr and 35°C is available for use as a coolant in a tube-in-shell heat exchanger with a surface area of 1.4 m^2 . The water is to be used to cool oil with a specific heat of $2.1 \text{ kJ/kg}^\circ\text{C}$ from an initial temperature of 120°C . Because of other constraints, the exit water temperature cannot exceed 99°C . The overall heat transfer coefficient is $280 \text{ W/m}^\circ\text{C}$. Determine the maximum flowrate of oil which can be cooled under these conditions.

Thermodynamic Properties of Freon-12 (Dichlorodifluoromethane)^a

Saturated Freon-12

Temp. °C	Abs. Press. MPa <i>P</i>	Specific Volume m ³ /kg				Enthalpy kJ/kg				Entropy kJ/kg K		
		Sat. Liquid <i>v_f</i>	Evap. <i>v_{fg}</i>	Sat. Vapor <i>v_g</i>	Sat. Liquid <i>h_f</i>	Evap. <i>h_{fg}</i>	Sat. Vapor <i>h_g</i>	Sat. Liquid <i>s_f</i>	Evap. <i>s_{fg}</i>	Sat. Vapor <i>s_g</i>		
-90	0.0028	0.000 608	4.414 937	4.415 545	-43.243	189.618	146.375	-0.2084	1.0352	0.8268		
-85	0.0042	0.000 612	3.036 704	3.037 316	-38.968	187.608	148.640	-0.1854	0.9970	0.8116		
-80	0.0062	0.000 617	2.137 728	2.138 345	-34.688	185.612	150.924	-0.1630	0.9609	0.7979		
-75	0.0088	0.000 622	1.537 030	1.537 651	-30.401	183.625	153.224	-0.1411	0.9266	0.7855		
-70	0.0123	0.000 627	1.126 654	1.127 280	-26.103	181.640	155.536	-0.1197	0.8940	0.7744		
-65	0.0168	0.000 632	0.840 534	0.841 166	-21.793	179.651	157.857	-0.0987	0.8630	0.7643		
-60	0.0226	0.000 637	0.637 274	0.637 910	-17.469	177.653	160.184	-0.0782	0.8334	0.7552		
-55	0.0300	0.000 642	0.490 358	0.491 000	-13.129	175.641	162.512	-0.0581	0.8051	0.7470		
-50	0.0391	0.000 648	0.382 457	0.383 105	-8.772	173.611	164.840	-0.0384	0.7779	0.7396		
-45	0.0504	0.000 654	0.302 029	0.302 682	-4.396	171.558	167.163	-0.0190	0.7519	0.7329		
-40	0.0642	0.000 659	0.241 251	0.241 910	-0.000	169.479	169.479	-0.0000	0.7269	0.7269		
-35	0.0807	0.000 666	0.194 732	0.195 398	4.416	167.368	171.784	0.0187	0.7027	0.7214		
-30	0.1004	0.000 672	0.158 703	0.159 375	8.854	165.222	174.076	0.0371	0.6795	0.7165		
-25	0.1237	0.000 679	0.130 487	0.131 166	13.315	163.037	176.352	0.0552	0.6570	0.7121		
-20	0.1509	0.000 685	0.108 162	0.108 847	17.800	160.810	178.610	0.0730	0.6352	0.7082		
-15	0.1826	0.000 693	0.090 326	0.091 018	22.312	158.534	180.846	0.0906	0.6141	0.7046		
-10	0.2191	0.000 700	0.075 946	0.076 646	26.851	156.207	183.058	0.1079	0.5936	0.7014		
-5	0.2610	0.000 708	0.064 255	0.064 963	31.420	153.823	185.243	0.1250	0.5736	0.6986		
0	0.3086	0.000 716	0.054 673	0.055 389	36.022	151.376	187.397	0.1418	0.5542	0.6960		
5	0.3626	0.000 724	0.046 761	0.047 485	40.659	148.859	189.518	0.1585	0.5351	0.6937		
10	0.4233	0.000 733	0.040 180	0.040 914	45.337	146.265	191.602	0.1750	0.5165	0.6916		
15	0.4914	0.000 743	0.034 671	0.035 413	50.058	143.586	193.644	0.1914	0.4983	0.6897		
20	0.5673	0.000 752	0.030 028	0.030 780	54.828	140.812	195.641	0.2076	0.4803	0.6879		
25	0.6516	0.000 763	0.026 091	0.026 854	59.653	137.933	197.586	0.2237	0.4626	0.6863		
30	0.7449	0.000 774	0.022 734	0.023 508	64.539	134.936	199.475	0.2397	0.4451	0.6848		
35	0.8477	0.000 786	0.019 855	0.020 641	69.494	131.805	201.299	0.2557	0.4277	0.6834		
40	0.9607	0.000 798	0.017 373	0.018 171	74.527	128.525	203.051	0.2716	0.4104	0.6820		
45	1.0843	0.000 811	0.015 220	0.016 032	79.647	125.074	204.722	0.2875	0.3931	0.6806		
50	1.2193	0.000 826	0.013 344	0.014 170	84.868	121.430	206.298	0.3034	0.3758	0.6792		
55	1.3663	0.000 841	0.011 701	0.012 542	90.201	117.565	207.766	0.3194	0.3582	0.6777		
60	1.5259	0.000 858	0.010 253	0.011 111	95.665	113.443	209.109	0.3355	0.3405	0.6760		
65	1.6988	0.000 877	0.008 971	0.009 847	101.279	109.024	210.303	0.3518	0.3224	0.6742		
70	1.8858	0.000 897	0.007 828	0.008 725	107.067	104.255	211.321	0.3683	0.3038	0.6721		
75	2.0874	0.000 920	0.006 802	0.007 723	113.058	99.068	212.126	0.3851	0.2845	0.6697		
80	2.3046	0.000 946	0.005 875	0.006 821	119.291	93.373	212.665	0.4023	0.2644	0.6667		
85	2.5380	0.000 976	0.005 029	0.006 005	125.818	87.047	212.865	0.4201	0.2430	0.6631		
90	2.7885	0.001 012	0.004 246	0.005 258	132.708	79.907	212.614	0.4385	0.2200	0.6585		
95	3.0569	0.001 056	0.003 508	0.004 563	140.068	71.658	211.726	0.4579	0.1946	0.6526		
100	3.3440	0.001 113	0.002 790	0.003 903	148.076	61.768	209.843	0.4788	0.1655	0.6444		
105	3.6509	0.001 197	0.002 045	0.003 242	157.085	49.014	206.099	0.5023	0.1296	0.6319		
110	3.9784	0.001 364	0.001 098	0.002 462	168.059	28.425	196.484	0.5322	0.0742	0.6064		
112	4.1155	0.001 792	0.000 005	0.001 797	174.920	0.151	175.071	0.5651	0.0004	0.5655		

*Copyright 1955 and 1956, E. I. du Pont de Nemours & Company, Inc. Reprinted by permission. Adapted from English units.

Superheated Freon-12

Temp. °C	v m³/kg	h kJ/kg	s kJ/kg K	v m³/kg	h kJ/kg	s kJ/kg K	v m³/kg	h kJ/kg	s kJ/kg K
		0.05 MPa			0.10 MPa			0.15 MPa	
-20.0	0.341 857	181.042	0.7912	0.167 701	179.861	0.7401			
-10.0	0.356 227	186.757	0.8133	0.175 222	185.707	0.7628	0.114 716	184.619	0.7318
0.0	0.370 508	192.567	0.8350	0.182 647	191.628	0.7849	0.119 866	190.560	0.7543
10.0	0.384 716	198.471	0.8562	0.189 994	197.628	0.8064	0.124 932	196.762	0.7763
20.0	0.398 863	204.469	0.8770	0.197 277	203.707	0.8275	0.129 930	202.927	0.7977
30.0	0.412 959	210.557	0.8974	0.204 506	209.866	0.8482	0.134 873	209.160	0.8186
40.0	0.427 012	216.733	0.9175	0.211 691	216.104	0.8684	0.139 768	215.463	0.8390
50.0	0.441 030	222.997	0.9372	0.218 839	222.421	0.8883	0.144 625	221.835	0.8591
60.0	0.455 017	229.344	0.9565	0.225 955	228.815	0.9078	0.149 450	228.277	0.8787
70.0	0.468 978	235.774	0.9755	0.233 044	235.285	0.9269	0.154 247	234.789	0.8980
80.0	0.482 917	242.282	0.9942	0.240 111	241.829	0.9457	0.159 020	241.371	0.9169
90.0	0.496 838	248.868	1.0126	0.247 159	248.446	0.9642	0.163 774	248.020	0.9354
		0.20 MPa			0.25 MPa			0.30 MPa	
0.0	0.088 608	189.669	0.7320	0.069 752	188.644	0.7139	0.057 150	187.583	0.6984
10.0	0.092 550	195.878	0.7543	0.073 024	194.969	0.7366	0.059 984	194.034	0.7216
20.0	0.096 418	202.135	0.7760	0.076 218	201.322	0.7587	0.062 734	200.490	0.7440
30.0	0.100 228	208.446	0.7972	0.079 350	207.715	0.7801	0.065 418	206.969	0.7658
40.0	0.103 989	214.814	0.8178	0.082 431	214.153	0.8010	0.068 049	213.480	0.7869
50.0	0.107 710	221.243	0.8381	0.085 470	220.642	0.8214	0.070 635	220.030	0.8075
60.0	0.111 397	227.735	0.8578	0.088 474	227.185	0.8413	0.073 185	226.627	0.8276
70.0	0.115 055	234.291	0.8772	0.091 449	233.785	0.8608	0.075 705	233.273	0.8473
80.0	0.118 690	240.910	0.8962	0.094 398	240.443	0.8800	0.078 200	239.971	0.8665
90.0	0.122 304	247.593	0.9149	0.097 327	247.160	0.8987	0.080 673	246.723	0.8853
100.0	0.125 901	254.339	0.9332	0.100 238	253.936	0.9171	0.083 127	253.530	0.9038
110.0	0.129 483	261.147	0.9512	0.103 134	260.770	0.9352	0.085 566	260.391	0.9220
		0.40 MPa			0.50 MPa			0.60 MPa	
20.0	0.045 836	198.762	0.7199	0.035 646	196.935	0.6999	0.030 422	202.116	0.7063
30.0	0.047 971	205.428	0.7423	0.037 464	203.814	0.7230	0.031 966	209.154	0.7291
40.0	0.050 046	212.095	0.7639	0.039 214	210.656	0.7452	0.033 450	216.141	0.7511
50.0	0.052 072	218.779	0.7849	0.040 911	217.484	0.7667	0.034 887	223.104	0.7723
60.0	0.054 059	225.488	0.8054	0.042 565	224.315	0.7875	0.036 285	230.062	0.7929
70.0	0.056 014	232.230	0.8253	0.044 184	231.161	0.8077	0.037 653	237.027	0.8129
80.0	0.057 941	239.012	0.8448	0.045 774	238.031	0.8275	0.038 995	244.009	0.8324
90.0	0.059 846	245.837	0.8638	0.047 340	244.932	0.8467	0.040 316	251.016	0.8514
100.0	0.061 731	252.707	0.8825	0.048 886	251.869	0.8656	0.041 619	258.053	0.8700
110.0	0.063 600	259.624	0.9008	0.050 415	258.845	0.8840	0.042 907	265.124	0.8882
120.0	0.065 455	266.590	0.9187	0.051 929	265.862	0.9021	0.044 181	272.231	0.9061
130.0	0.067 298	273.605	0.9364	0.053 430	272.923	0.9198			
		0.70 MPa			0.80 MPa			0.90 MPa	
40.0	0.026 761	207.580	0.7148	0.022 830	205.924	0.7016	0.019 744	204.170	0.6982
50.0	0.028 100	214.745	0.7373	0.024 068	213.290	0.7248	0.020 912	211.765	0.7131
60.0	0.029 387	221.854	0.7590	0.025 247	220.558	0.7469	0.022 012	219.212	0.7358
70.0	0.030 632	228.931	0.7799	0.026 380	227.766	0.7682	0.023 062	226.564	0.7575
80.0	0.031 843	235.997	0.8002	0.027 477	234.941	0.7888	0.024 072	233.856	0.7785
90.0	0.033 027	243.066	0.8199	0.028 545	242.101	0.8088	0.025 051	241.113	0.7987
100.0	0.034 189	250.146	0.8392	0.029 588	249.260	0.8283	0.026 005	248.355	0.8184
110.0	0.035 532	257.247	0.8579	0.030 612	256.428	0.8472	0.026 937	255.593	0.8376
120.0	0.036 458	264.374	0.8763	0.031 619	263.613	0.8657	0.027 851	262.839	0.8562
130.0	0.037 572	271.531	0.8943	0.032 612	270.820	0.8838	0.028 751	270.100	0.8745
140.0	0.038 673	278.720	0.9119	0.033 592	278.055	0.9016	0.029 639	277.381	0.8923
150.0	0.039 764	285.946	0.9292	0.034 563	285.320	0.9189	0.030 515	284.687	0.9098
		1.00 MPa			1.20 MPa			1.40 MPa	
50.0	0.018 366	210.162	0.7021	0.014 483	206.661	0.6812	0.012 579	211.457	0.6876
60.0	0.019 410	217.810	0.7254	0.015 463	214.805	0.7060	0.013 448	219.822	0.7123
70.0	0.020 397	225.319	0.7476	0.016 368	222.687	0.7293	0.014 247	227.891	0.7355
80.0	0.021 341	232.739	0.7689	0.017 221	230.398	0.7514	0.014 997	235.766	0.7575
90.0	0.022 251	240.101	0.7895	0.018 032	237.995	0.7727	0.015 710	243.512	0.7785
100.0	0.023 133	247.430	0.8094	0.018 812	245.518	0.7931	0.016 393	251.170	0.7988
110.0	0.023 993	254.743	0.8287	0.019 567	252.993	0.8129	0.017 053	258.770	0.8183
120.0	0.024 835	262.053	0.8475	0.020 301	260.441	0.8320	0.017 695	266.334	0.8373
130.0	0.025 661	269.369	0.8659	0.021 018	267.875	0.8507	0.018 321	273.877	0.8558
140.0	0.026 474	276.699	0.8839	0.021 721	275.307	0.8689	0.018 934	281.411	0.8738
150.0	0.027 275	284.047	0.9015	0.022 412	282.745	0.8867	0.019 535	288.946	0.8914
160.0	0.028 068	291.419	0.9187	0.023 093	290.195	0.9041			
		1.60 MPa			1.80 MPa			2.00 MPa	
70.0	0.011 208	216.650	0.6959	0.009 406	213.049	0.6794	0.008 704	218.859	0.6909
80.0	0.011 984	225.177	0.7204	0.010 187	222.198	0.7057	0.009 406	228.056	0.7166
90.0	0.012 698	233.390	0.7433	0.010 884	230.835	0.7298	0.010 035	236.760	0.7402
100.0	0.013 366	241.397	0.7651	0.011 526	239.155	0.7524	0.010 615	245.154	0.7624
110.0	0.014 000	249.264	0.7859	0.012 126	247.264	0.7739	0.011 159	253.341	0.7835
120.0	0.014 608	257.035	0.8059	0.012 697	255.228	0.7944	0.011 676	261.384	0.8037
130.0	0.015 195	264.742	0.8253	0.013 244	263.094	0.8141	0.012 172	269.327	0.8232
140.0	0.015 765	272.406	0.8440	0.013 772	270.891	0.8352	0.012 651	277.201	0.8420
150.0	0.016 320	280.044	0.8623	0.014 284	278.642	0.8518			